

Guardian Building Products has had **Loft Guard®** – Guardian’s virgin white fiberglass loft / attic loosefill insulation for pneumatic application tested at:

BRE

Building Research Establishment, Ltd.
Garston, Watford, Herts, WD25 9XX
United Kingdom

Testing was to the following EU standards for product reaction to combustibility and fire:

BS EN 13501-1:2007 - Test Report No. 242238
BS EN ISO 1182:2002 - Test Report No. 242235
BS EN ISO 1716:2002 - Test Report No. 240715

In compliance with the above standards, on 01 December 2007 the BRE determined Loft Guard to have a fire & combustibility rating of: **A1**

Joseph Church
Dir. Business & Product Development
Guardian Building Products